

IDMC, ANAND	CORRIGENDUM-I Dt. 15.09.2026	TENDER REF: IDMC/ Sourcing & VD/ 2026-27/ Enquiry/ 338 dated 31.08.2026
--------------------	---	--

Tender/Event Reference: IDMC/ Sourcing & VD/ 2026-27/Enquiry/ 338 dated 31.08.2026

Description of Work: CIVIL, STRUCTURAL & OTHER ANCILLARY WORKS i.e.; WATER SUPPLY, SANITARY, STORM WATER, DRAINAGE & INTERNAL ELECTRIFICATION WORKS FOR PANEER PLANT AT MOTHER DAIRY FRUITS AND VEGETABLES PVT. LTD.-ETAWAH, UTTAR PRADESH

Please note the following changes in the bidding document.

Corrigendum			
Sl. No.	Tender Document Section & Clause	As per the tender document	Please read it as below (Revision)
1	Section 0 Clause No.5 (e), (f), (l)	Event Close Date & time - 15.09.2026, 17.00 Hours Last Date and time for bid submission - 15.09.2026, 17.00 Hours Date and time for receipt of EMD - 14.09.2026, 17.00 Hours	Event Close Date & time - 22.09.2026, 17.00 Hours Last Date and time for bid submission - 22.09.2026, 17.00 Hours Date and time for receipt of EMD - 21.09.2026, 17.00 Hours
2	Section X – of Schedule Quantities.	Item No. 4.01A: Unit of measurement as mentioned is Nos.	unit should be in Sq. M. instead of Nos. Please consider SQM instead of Nos.
3	Section X – of Schedule Quantities.	Item No.4.38: Providing and fixing of SS 304 door single/double leaf of approved make including providing shop drawing, fabrication as per approved shop drawing, tool and tackle, door closer, lock arrangement, viewing panel, door handle etc. all complete as per approved manufacture specification as directed by engineer in charge.	Please find attached detail for item No.4.38
4	Section X – of Schedule Quantities.	Item 5.02 “-Do- as per Item No.5.01 but for 19 mm thick plain cement plaster” but item 5.01 is not in BOQ	Detail of Item No.5.01:Providing and applying 12 mm thick plain cement plaster finish at all heights and below highest plinth level in Cement Mortar (CM) 1:4

IDMC, ANAND	CORRIGENDUM-I Dt. 15.09.2026	TENDER REF: IDMC/ Sourcing & VD/ 2026-27/ Enquiry/ 338 dated 31.08.2026
--------------------	---	--

			(1 part cement: 4 parts sand-50% coarse and 50% fine) in line, level and plumb to the walls, concrete elements, beams, ceiling, stair, columns, pardis, including making plaster bands, stripes, molds, pattas, grooves etc, over any brick or concrete surface as specified including scaffolding, curing and finishing smooth Including hacking of concrete surface, complete as directed.
5	Section X – Schedule of Quantities.	Item 6.54C “ Do – as per item no. 6.54A but providing and laying minimum 20 mm thick premium/1st quality stain resistant ENDURA tiles. But item 6.54A not in BOQ.	Detail of Item No.6.54A: Providing and laying minimum 12mm thick premium/1st quality stain resistant ENDURA tiles of M/s H & R Johnson (India) having MOH hardness minimum 7, flexural strength minimum 35 N/Sq.mm, breaking strength as minimum 1700 N, density 2.2 gm/CC as minimum and having size 300 X 300 or as approved size, colour and shade having plain edges in flooring over average 37mm thick cement mortar 1:4 (1 part cement: 4 part coarse sand) bed laid to requisite, line, level and slope, fixed with approved adhesive (Diamond Star), making joints of 5 to 8 mm and fill with epoxy grout of same product, cleaning the area with water or water with mild acid etc complete as directed.

Note:

1. The above corrigendum shall form part of the bidding document. All other terms & conditions shall remain unchanged.
2. The bidders are requested to submit their bids before the due date and time.

Issued by: IDMC Limited, Anand

Enclosure: SS Door Specification

Stainless Steel (SS)



Technical Specifications:

Type:

Flush & insulated metal doors

Door leaf material:

SS 304

Door leaf core material:

Polyisocyanurate (PIR)

Door blade thickness:

44 mm

Door handle:

SS 304, D Type

Door Closer:

ASSA ABLOY DC116

Wall Frame:

2.5mm thick Anodized Alu 6063 with 2.0mm thick GI reinforcement

Lock:

Dead lock with European norm cylinder

View panel:

Double insulated glass unit flushed with door's faces.
Size- 300x300mm

Gasket:

Rubber gasket non particle shedding type

Hinges

SS 304 Ball bearing hinges

Finishes Available

2B, Hairline, Circle Brush

Sizes Available:

Single Leaf:

- Widths- 600 to 1170mm
- Height- 1800 to 2400mm

Double Leaf:

- Widths- 1200 to 2200mm
 - Height- 1800 to 2400mm
- (other sizes available on request)

Options Available

- Mortice Lock with Lever handle
- Automation : For Single leaf & Double leaf
- Concealed Drop Seal
- Door Closer on Passive leaf with Door Coordinator for double leaf doors.
- Door Stopper- Floor Mounted/Wall Mounted

Metaflex. Meet reliability.